

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

LISTING No. 7165-0328:155 Page 1 of 1

CATEGORY: Control Units (Non High-Rise)

LISTEE: Potter, 2081 Craig Road, St. Louis MO 63146  
Contact: Brad Serangeli (314) 878-4321

DESIGN: Model PFC-5002, PFC-5004 and PFC-5004E fire alarm control units. Non-coded; automatic, manual, local, remote station, central station, waterflow and sprinkler supervisory service. System components:

PFC-5002, -5004, -5004E	Main Fire Alarm Assembly
DM-204	Initiating & NAC Zones
RM-204, RM-208	Relay Module
PR-100	Polarity reversal & City Tie
DACT-100	DACT
BB-815, BB-816	Enclosure

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control units for use with separately listed electrically and functionally compatible initiating and indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to listee's Installation instructions Manual for details.

NOTE: For **Fire Alarm Verification Feature**, the maximum Retard/Reset/Restart period shall not exceed 30.0 seconds.

XLF: 7165-1477:109

09-11-2001



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 20, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy  
Program Manager